

2024 Water Quality Report for the Village of Pinckney

Water Supply Serial Number: MI0005322

This report covers the drinking water quality for the Village of Pinckney for the 2024 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2024. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (U.S. EPA) and state standards.

Our water source is from two groundwater wells that were installed in 1990 at a depth of 200ft each. Both wells are 12-in production wells that have a 500 gallon per minute rating.

In June of 1997 the VOP established a Wellhead Protection Plan, a voluntary program to protect our source water from potential sources of groundwater contamination. To help indicate the susceptibility of the groundwater to contamination, we have tested our source water for tritium. Tritium is a naturally occurring isotope whose presence increased as a result of nuclear weapons testing in the 1950's causing groundwater to be "tagged" with excess tritium. Groundwater recharged prior to the 1950's will have a tritium level at or below one "tritium unit" (TU). Our system detected tritium at <0.8 and may be considered not as vulnerable to contamination as water with higher tritium levels. Although tritium levels may indicate an aquifer is "not vulnerable," it is important to realize that a potential for contamination may still exist.

Contaminants and their presence in water: Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (800-426-4791).


Vulnerability of sub-populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking

water from their health care providers. U.S. EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Sources of drinking water: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.



Water Quality Data

In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

The table below lists all the drinking water contaminants that we detected during the 2024 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2024. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **N/A:** Not applicable
- **ND:** not detectable at testing limit
- **ppm:** parts per million or milligrams per liter
- **ppb:** parts per billion or micrograms per liter
- **ppt:** parts per trillion or nanograms per liter
- **pCi/l:** picocuries per liter (a measure of radioactivity)
- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow. 1Monitoring Data for Regulated Contaminants
- **Level 1 Assessment:** A study of the water supply to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- **Level 2 Assessment:** A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Arsenic (ppb)	10	0	8	N/A	2024	NO	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.095	N/A	2021	NO	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Nitrate (ppm)	10	10	ND	N/A	2024	NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Fluoride (ppm)	4	4	0.26	N/A	2023	NO	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium ¹ (ppm)	N/A	N/A	16	N/A	2023	NO	Erosion of natural deposits
Chlorine (ppm)	4	4	0.23	0.11 +/- 0.35	2024	NO	Water additive used to control microbes
TTHM Total Trihalomethanes (ppb)	80	N/A	21	N/A	2024	NO	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	5	N/A	2024	NO	Byproduct of drinking water disinfection
Synthetic Organic Chemical	N/A	N/A	ND	N/A	2024	NO	Chemical run-off from fields
Volatile Organic Compound	N/A	N/A	ND	N/A	2024	NO	Chemical run-off from fields
Alpha Emitters (pCi/L)	15	0	0.7	N/A	2024	NO	Erosion of natural deposits
Combined radium (pCi/L)	5	0	2.6	N/A	2019	NO	Erosion of natural deposits
Uranium (ppb)	30	0	0.3	N/A	2024	NO	Erosion of natural deposits
Total Coliform	TT	N/A	N/A	N/A	2024	NO	Naturally present in the environment
E. coli in the distribution system (positive samples)	See E. coli note ²	0		N/A		NO	Human and animal fecal waste
Fecal Indicator – E. coli at the source (positive samples)	TT	N/A		N/A		NO	Human and animal fecal waste

¹ Sodium is not a regulated contaminant.

² E. coli MCL violation occurs if: (1) routine and repeat samples are total coliform-positive and either is E. coli-positive, or (2) the supply fails to take all required repeat samples following E. coli-positive routine sample, or (3) the supply fails to analyze total coliform-positive repeat sample for E. coli.

Per- and polyfluoroalkyl substances (PFAS)									
Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant		
Hexafluoropropylene oxide dimer acid (HFPO-DA) (ppt)	370	N/A	ND	N/A	2024	NO	Discharge and waste from industrial facilities utilizing the Gen X chemical process		
Perfluorobutane sulfonic acid (PFBS) (ppt)	420	N/A	ND	N/A	2024	NO	Discharge and waste from industrial facilities; stain-resistant treatments		
Perfluorohexane sulfonic acid (PFHxS) (ppt)	51	N/A	ND	N/A	2024	NO	Firefighting foam; discharge and waste from industrial facilities		
Perfluorohexanoic acid (PFHxA) (ppt)	400,000	N/A	ND	N/A	2024	NO	Firefighting foam; discharge and waste from industrial facilities		
Perfluorononanoic acid (PFNA) (ppt)	6	N/A	ND	N/A	2024	NO	Discharge and waste from industrial facilities; breakdown of precursor compounds		
Perfluorooctane sulfonic acid (PFOS) (ppt)	16	N/A	ND	N/A	2024	NO	Firefighting foam; discharge from electroplating facilities; discharge and waste from industrial facilities		
Perfluorooctanoic acid (PFOA) (ppt)	8	N/A	ND	N/A	2024	NO	Discharge and waste from industrial facilities; stain-resistant treatments		
Inorganic Contaminant Subject to Action Levels (AL)	Action Level	MCLG	Your Water ³	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant		
Lead (ppb)	15	0	0	N/A	2023	NO	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits		
Copper (ppm)	1.3	1.3	0.3	.029-.33	2023	NO	Corrosion of household plumbing systems; Erosion of natural deposits		

³ Ninety (90) percent of the samples collected were at or below the level reported for our water.

Information about lead: *Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The Village of Pinckney is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water and wish to have your water tested, contact the Village of Pinckney at d.moma@villageofpinckney.org for available resources. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.*

While your drinking water meets the U.S. EPA standard for arsenic, it does contain low levels of arsenic. The U.S. EPA standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at the VOP office at 220 South Howell, Pinckney, MI. Office hours are 8:00am to 4:00pm Monday through Thursday. This report will not be mailed to individual customers. It can be viewed at the VOP offices or website, Public Library, Post Office, WellBridge of Pinckney, or the Livingston County Health Department.

We invite public participation in decisions that affect drinking water quality. You can attend the VOP regular scheduled council meetings, on the second and fourth Monday of each month at 7:00pm at 220 South Howell, Pinckney, MI. For more information about your water or the contents of this report, contact Dustin Moma via email at d.moma@villageofpinckney.org. For more information about safe drinking water, visit the U.S. EPA at <http://www.epa.gov/safewater>.