



Brian Jonckheere

Livingston County Drain Commissioner

2300 E. Grand River Ave., Ste. 105

Howell, MI 48843-7581

Phone: 517-546-0040 FAX: 517-545-9658

Website: www.milivcounty.gov/drain Email: drain@livgov.com

January 2, 2025

Mr. Danny Kekhwa
51483 Times Square Drive
Shelby Township, MI 48315

Re: Essence - Pinckney
Construction Plans Resubmittal
Southeast 1/4 of Section 23
Village of Pinckney

Dear Mr. Kekhwa:

I received revised Construction Plans for the above referenced project er via email on December 30, 2024. The submitted information has been reviewed for conformance with the current L.C.D.C. "Procedures and Design Criteria for Stormwater Management Systems" and with our office's last review letter dated December 26, 2024.

The comments in the review letter have been adequately addressed on the revised plans with one exception. The proposed 4" pipe restriction in the 8" detention basin outlet pipe noted on Sheet C-05 should be eliminated, to minimize the potential usage of the basin's overflow spillway.

I am granting approval of the plans for Essence - Pinckney. This approval is contingent on the aforementioned item being addressed in revised hard copy construction plans submitted to this office with your soil erosion control permit application packet.

Very truly yours,

A handwritten signature in black ink, appearing to read "K. Recker".

Kenneth E. Recker, II, P.E.
Chief Deputy Drain Commissioner

CC: Paul Lewsley, Spaulding DeDecker
Marco Lytwyn, M36 Development, LLC
Jesse Lewter, Wolverine Engineering
Jeffrey Buerman, Village of Pinckney President

