

Amendment to Village of Pinckney, *Technical Standards for Design and Construction*, SECTION 01 20 04, *WATER SYSTEM DESIGN REQUIREMENTS*, PART 1, *GENERAL*, Section 1.04, *WATERMAIN DESIGN CRITERIA*, Subsection K, *Connections to the Public Water Supply System*, to read as follows:

**K. Connections to the Public Water Supply System:**

1. All connections to the Village of Pinckney public water supply system shall be in accordance with Pinckney Code of Ordinances 51.06 - Connections to Water Supply System, and Section 33 14 16 - Water Piping, and the following:
  - a. Water connections shall not be made unless:
    - i. The water main extends across the total frontage of the parcel to be served;
    - ii. The water main extends across the total frontage of the parcel facing one street in the case of a corner parcel; or
    - iii. The water main abuts the parcel to be served on a non-frontage parcel line.
  - b. Upon connection of any property to the Water Supply System, any private water well serving the property shall be disconnected from the distribution system to prevent cross-contamination and shall be abandoned in accordance with applicable law.