

DPW MONTH END REPORT

WATER

- Daily Reads
- Bac-T Samples
- MOR Completed for Month
- Cross Connection Report Submitted
- Consumer Confidence Report Submitted For Review

SEWER

- Daily Reads
- Pond Samples
- Ferric Chloride delivery
- DMR Completed for Month

DPW/STREETS/MISC

- Road Salt Delivery
- Sidewalk Repair Inventory List

POND SAMPLE RESULTS

- Sodium: 130 PPM Limitation: 400 PPM
- Phosphorus: 0.22 PPM Limitation: 1.0 PPM

BAC-T SAMPLE RESULTS

- Total Coliform: Absent On All Samples