

## DPW MONTH END REPORT

### WATER

- Daily Reads
- Bac-T Samples
- MOR Completed for Month

### SEWER

- Daily Reads
- Pond Samples
- High School Effluent Sample
- Sand Filter Bed Effluent Sample
- DMR Completed for Month
- Solar Bee Maintenance
- Root Cutting of Sewer Mains

### DPW/STREETS/MISC

- Install New Street Signs Throughout Town
- First Brush Pick-Up
- Spring Clean-Up
- Pot Hole Fill

### POND SAMPLE RESULTS

- Sodium: 140 PPM    Limitation: 400 PPM
- Phosphorus: 0.24 PPM    Limitation: 1.0 PPM

### BAC-T SAMPLE RESULTS

- Total Coliform: Absent On All Samples