

## DPW MONTH END REPORT

### WATER

- Daily Reads
- Bac-T Samples
- MOR Completed for Month
- Well House Generator Maintenance
- Test Well Bid Acquisition

### SEWER

- Daily Reads
- Pond Samples
- Monitoring Wells Sample
- DMR Completed for Month
- Lift Station Cleaning

### DPW/STREETS/MISC

- Brush Pick-Up
- Removal Of Sidewalks In Village Edge

### POND SAMPLE RESULTS

- Sodium: 140 PPM    Limitation: 400 PPM
- Phosphorus: 0.24 PPM    Limitation: 1.0 PPM

### BAC-T SAMPLE RESULTS

- Total Coliform: Absent On All Samples