

DPW MONTH END REPORT

WATER

- Daily Reads
- Bac-T Samples
- MOR Completed for Month
- Annual Monitoring Schedule Sampling
- Valve Turning

SEWER

- Daily Reads
- Pond Samples
- DMR Completed for Month

DPW/STREETS/MISC

- Brush Pick-Up
- Sidewalk Remove and Replace Completed

POND SAMPLE RESULTS

- Sodium: 140 PPM Limitation: 400 PPM
- Phosphorus: 0.13 PPM Limitation: 1.0 PPM

BAC-T SAMPLE RESULTS

- Total Coliform: Absent On All Samples