

## DPW MONTH END REPORT

### WATER

- Daily Reads
- Bac-T Samples
- MOR Completed for Month
- Hydrants Pumped For Winter

### SEWER

- Daily Reads
- Pond Samples
- DMR Completed for Month
- Solar B Mixer Maintenance
- Brush Clearing of Deep Underdrains

### DPW/STREETS/MISC

- S. Howell St. Resurface
- Pothole Fill
- N. Howell St. Corner Demo and Replace
- Leaf Pick-Up Begin

### POND SAMPLE RESULTS

- Sodium: 150 PPM    Limitation: 400 PPM
- Phosphorus: 0.14 PPM    Limitation: 1.0 PPM

### BAC-T SAMPLE RESULTS

- Total Coliform: Absent On All Samples