

DPW MONTH END REPORT

WATER

- Daily Reads
- Bac-T Samples
- MOR Completed for Month
- Continued Progress For New Well Development

SEWER

- Daily Reads
- Pond Samples
- DMR Completed for Month
- Monitoring Wells Samples

DPW/STREETS/MISC

- Last Brush Pick-Up
- Last Leaf Pick-Up
- Switched Equipment to Winter Ready
- Pole Garland Installed
- Winter Banners Hung

POND SAMPLE RESULTS

- Sodium: 160 PPM Limitation: 400 PPM
- Phosphorus: 0.17 PPM Limitation: 1.0 PPM

BAC-T SAMPLE RESULTS

- Total Coliform: Absent On All Samples