

DPW MONTH END REPORT

WATER

- Daily Reads
- Bac-T Samples
- MOR Completed for Month
- Annual EGLE Water Sampling
- Work On Water Asset Management Plan
- EGLE Water Permit Issued For Lakeland Knoll

SEWER

- Daily Reads
- Pond Samples
- DMR Completed for Month
- Transducer Replacement Lift Station 4
- Pull Rags From Lift Station 1
- Pull Rags From Lift Station 3

DPW/STREETS/MISC

- Pot Hole Fill
- Brush Removal

POND SAMPLE RESULTS

- Sodium: 140 PPM Limitation: 400 PPM
- Phosphorus: 0.29 PPM Limitation: 1.0 PPM

BAC-T SAMPLE RESULTS

- Total Coliform: Absent On All Samples