

## DPW MONTH END REPORT

### WATER

- Daily Reads
- Bac-T Samples
- MOR Completed for Month
- Work On Water Asset Management Plan
- PFAS Samples
- Valve Exercising Completed

### SEWER

- Daily Reads
- Pond Samples
- DMR Completed for Month
- Begin Annual Jet Rodding
- Delivery of Vac Truck

### DPW/STREETS/MISC

- Brush Removal
- Equipment Maintenance
- Brush Clearing In Cemetery

### POND SAMPLE RESULTS

- Sodium: 140 PPM      Limitation: 400 PPM
- Phosphorus: 0.19 PPM      Limitation: 1.0 PPM

### BAC-T SAMPLE RESULTS

- Total Coliform: Absent On All Samples