

DPW MONTH END REPORT

WATER

- Daily Reads
- Bac-T Samples
- MOR Completed for Month
- Work On Water Asset Management Plan
- Winterize Hydrants
- Annual Cathodic Protection Inspection
- Submit To EGLE Cross Connection Control Program
- Submit To EGLE Water Asset Management Plan

SEWER

- Daily Reads
- Pond Samples
- DMR Completed for Month
- High School Sample
- Remove Rags From Lift Station Pump

DPW/STREETS/MISC

- Brush Removal
- Equipment Maintenance
- Leaf Pick-Up
- Pothole Fill
- MS4 Storm Water Inspection

POND SAMPLE RESULTS

- Sodium: 140 PPM Limitation: 400 PPM
- Phosphorus: 0.23 PPM Limitation: 1.0 PPM

BAC-T SAMPLE RESULTS

- Total Coliform: Absent On All Samples