

DPW MONTH END REPORT

WATER

- Daily Reads
- Bac-T Samples
- MOR Completed for Month

SEWER

- Daily Reads
- Pond Samples
- DMR Completed for Month

DPW/STREETS/MISC

- SNOW
- Equipment Maintenance
- SNOW
- Shop Maintenance

POND SAMPLE RESULTS

- Sodium: 190 PPM Limitation: 400 PPM
- Phosphorus: 0.16 PPM Limitation: 1.0 PPM

BAC-T SAMPLE RESULTS

- Total Coliform: Absent On All Samples